

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-1062:130 Page 1 of 1

CATEGORY: Audible Devices

LISTEE: Detection Systems, Inc., 130 Perinton Parkway, Fairport, NY 14450
Contact: Frank Mioduszewski *(585) 223-4060

DESIGN: Model GEH24 horn and Models HS24-15, HS24-15/75, HS24-30, HS24-60, HS24-75, HS24-110, GEC24-15, GEC24-15/75, GEC24-30, GEC24-60, GEC24-75 and GEC24-110 horn strobes. May be followed by -W (wall) and -W or -R (white or red). Refer to listee's data sheet for additional product description and operational considerations.

RATING: Electrical: 24 VDC
Candela: 15cd, 15/75cd, 30cd, 60cd, 75cd, 110cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as horn and horn/strobes for use with separately listed compatible fire alarm control units. For indoor use only.

Units can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition.

XLF: 7135-0569:122

*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 5, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager